

This is a scanned picture of the original document



aSENSE

Page 1(2)

Declaration of conformity

According to the EMC Directive 2004/108/EC

Type of equipment

CO₂ sensor

Brand name or trade mark

aSENSE

Type designation(s)/Model no(s)

040-8-00xx

Manufacturer's name, address, telephone & fax no

SenseAir AB

Box 96

SE-820 60 Delsbo, Sweden, Tel: + 46-653-717770, Fax: +46-653-71 77 89

The above stated equipment has been tested according to relevant parts of the following standards and has been found to comply with the required performance criteria stated therein.

Applicable standards:

EN 61326-1:2006 "Electrical equipment for measurement, control and laboratory use"

Emission: EN 61326-1:2006 class B equipment

Immunity: EN 61326-1:2006. Tested for basic immunity test requirements (table 1, part 6.2)

Compliant standards:

EN 61000-6-1:2007 "Immunity for residential, commercial and light-industrial environments"

EN 61000-6-3:2007 "Emission standard for residential, commercial and light-industrial environments"

Accordingly tests have been performed as specified in the following standards:

| Basic standard | Compliant | Test of |
|--|-----------------------------|---|
| CISPR 11:2007 - Industrial, scientific and medical equipment | Yes, class B, group 1 | Radio-frequency disturbance characteristics |
| CISPR 11:2007 | Yes, class B, group 1 | Conducted emission |
| IEC 61000-3-2:2005 | Not applicable ¹ | Limits for harmonic current emissions (equipment input current ≤ 16 A per phase). |
| IEC 61000-3-3:2008 | Not applicable ² | Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection. |

Note 1: Less than 75W. Note 2: Unlikely to produce significant voltage fluctuations or flicker.

This is a scanned picture of the original document



aSENSE

Page 2(2)

| Basic standard | Compliant | Test of immunity to |
|---------------------|-----------------------------|--|
| IEC 61000-4-3:2006 | Yes | Radiated, radio-frequency, electromagnetic field immunity test. |
| IEC 61000-4-6:2008 | Yes | Immunity to conducted disturbances, induced by radio-frequency fields. |
| IEC 61000-4-4:2004 | Yes | Electrical fast transient/burst immunity test. |
| IEC 61000-4-5:2005 | Yes | Surge immunity test. |
| IEC 61000-4-2:1995 | Yes, EN 61000-6-1:2007 | Electrostatic discharge immunity test. |
| IEC 61000-4-11:2004 | Yes | Voltage dips, short interruptions and voltage variations immunity tests. |
| IEC 61000-4-8:2009 | Not applicable ³ | Power frequency magnetic field immunity test. |

Note 3: Not applicable since the EUTs do not contain any devices which are sensitive to the specified levels of magnetic fields.

Additional information

The product is CE-marked in 2007.

As manufacturer/ the manufacturer's authorized representative established within EEA, we declare under our sole responsibility that the equipment follows the provisions of the Directives stated above

Date and place of issue

Delsbo 2010-03-29

Signature of authorized person

A handwritten signature in blue ink, appearing to read "Hans Martin", written over a faint grid background.

Name & Position

Hans Martin, R & D Manager